



88 Empire Drive • St. Paul, Minnesota • 55103  
 (651) 642-1150 • fax (651) 642-1239

## VOC Content Test Certificate

April 12, 2011

Supplier: Hilti Entwicklungsgesellschaft mbH  
 BU Chemicals  
 Hiltistrasse 6  
 86916 Kaufering  
 GERMANY

Sample Description: Hilti CP 680 Assembly

Date Tested: April 4, 2011

Test Method: SCAQMD method 304-91 "Determination of Volatile Organic Compounds (VOC) in Various Materials" as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168. The values also comply with the requirements of EPA test method #24.

Test Data:

Specification	Product
<b>LEED 2009 (LEED 3.0)</b> <b>LEED 2.2</b> IEQ-4.1: Low-Emitting Materials – Adhesives and Sealants	<b>Hilti</b> <b>CP 680 Assembly</b>
<b>Green Building Council of Australia</b> Green Star Office Design 3.0, IEQ-13 Green Star Office Design 2.0, IEQ-13 Green Star Office Interiors 1.1, IEQ-11	
<b>Architectural Sealant;</b> <b>VOC Limit: 250 g/L</b>	
<b>Product contains: 1.4 g/L of VOC</b>	

---

William Welbes  
*Vice President of Laboratory Operations*

---

Tom Barrett  
*Senior Chemist*